

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 8537-0113:017

Page 1 of 1

**CATEGORY:** Vibration Isolators

**LISTEE:** Duro Dyne of California, 15005 Marquardt Ave., Santa Fe Springs, CA 90670  
Contact: \*Deborah Scott (562) 926-1774 Fax (562) 926-5778

**DESIGN:** BLACK EXCELON Flexible Duct Vibration Isolator: vinyl coated, flame retardant with metal connectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name and product designation imprinted on carton.

**APPROVAL:** Listed for use in vibration isolators or flexible connectors in air handling systems. The fabric does not propagate flame beyond area exposed to source of ignition. Vibration isolators are plain or preassembled with 24 Ga. metal edges secured by means of double lock seams and are cut and bent to shape for the duct connection involved.

\*Rev. 05-08-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager